

Certificate of Compliance

Certificate: 70113203 **Master Contract:** 240436 (240436)

Project: 70183990 **Date Issued:** 2018-06-01

Issued to: Delta Electronics Inc

39 Section 2 Huandong Rd

Shanhua Township Tainan, 74144 TAIWAN

Attention: Ning Zhang

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Rohana Yang Rohana Yang

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Transformerless Grid Support Utility Interactive Inverter, M series. Models M8-TL-US, M6-TL-US, M5-TL-US and M4-TL-US, permanently connected.

Transformerless, Bi-directional, Stand-Alone or Grid Support Utility Interactive Inverter with charge controller, E series, models E8-TL-US, E6-TL-US, E8-TL-US(AC) and E6-TL-US(AC), with optional Auto Transfer Switch (ATS-5000) permanently connected.

Notes:

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No.107.1-01 - General Use Power Supplies

DQD 507 Rev. 2016-02-18

Page



 Certificate:
 70113203
 Master Contract:
 240436

 Project:
 70183990
 Date Issued:
 2018-06-01

*UL Std. No. 1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment For Use With Distributed Energy Sources (Second Edition, Revision December 22, 2017)

UL 1699B - Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue Number 2, January 14, 2013)

CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue Number 1, March 11, 2013)

*Note: Conformity to UL 1741(Second Edition, Revision December 22, 2017) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011), IEEE 1547.1a-2015, California Electric Rule 21, Hawaiian Electric Co. SRD-UL-1741-SA-V1.1 and Supplement SA.

DQD 507 Rev. 2016-02-18